



SITE INSPECTION FORM

NAME SITE # DATE

INSPECTED BY:

(Signatures)

ALL SITE IMPROVEMENTS, RV's, CAMPERs, TENTS, SCREEN ROOMS, 100 GALLON PROPANE TANKS, MUST BE AT LEAST FIVE (5) FEET FROM THE SETBACK LINE WITHOUT A DOCUMENTED VARIANCE ON FILE. ONLY APPROVED COLORS AND MATERIALS MAY BE USED. DEVIATIONS AND VARIANCES MUST BE NOTED BY THE INSPECTOR.

Table with columns for item description, approval status (None, Approve, Deny, Color, Material), and Problems - Remarks. Rows include items like RV PAD, TENT PLATFORM, SHED, DECK(S), GENERATOR COVER, KITCHEN CABINET, RETAINING WALL(S), STEPS, FENCE-PARTITION-WINDBREAK, 100 GALLON PROPANE TANK, FRENCH DRAIN, and SNOW ROOF conditions.



SITE SALE – FIRE & SAFETY		Fire pit	Stove	Other	None	Approve	Deny	Approved		Problems - Remarks
								Color	Material	
16	WOOD BURNING DEVICES									
	How many									
	Tree branches 15' above devices									
	15+' from LP and propane tanks									
	5' from combustibles/site boundary									
	5' gravel/DG perimeter									
	Metal cover to smother flames		n/a							
	5+' stove pipe w/ spark arrester	n/a								
	Concrete bottom		n/a							
	14" deep – minimum		n/a							
	Steel liner or fire brick									
	6" thick solid walls – min. 8" high		n/a							
	Under 25% concrete exterior		n/a							
	Approved for use									
17	SITE CLEAN-UP ↓ ↓									
	Pine needles cleaned & removed									
	Living Area									Entire Site
	Trees trimmed of dead limbs 15' high									
	No firewood stacked between or against trees									
	Storage of firewood limited to ½ cord (2' x 2' x 8')									
	Dead trees removed									
SITE SALE - INSPECTIONS						YES	NO			
18	Boundary Markers – metal & obvious									
19	All 5' setbacks observed									
	All improvements approved									
	All variances documented									
20	General Campsite Appearance									
21	Site Measurements (as attached)									
22	Cabover Camper grandfathered only until the Membership sells. Needs to be removed									
ADDITIONAL COMMENTS:										